

Exhibit A

Outside Air Ventilation and MERV-13 Filters

(Based on Information as of 7/16/21)

Institution	Total Number of Housing Units	Number of Housing Units <u>with</u> MERV-13 Filters Installed ¹	Number of Housing Units <u>without</u> MERV-13 Filters Installed ²	Number of Housing Units Currently Using 100% Outside Air
ASP	24	24	0	0
CAC	10	10	0	0
CAL	23	23	0	0
CCC	21	18	3	6
CCI	22	1	21	22
CCWF	16	0	16	16
CEN	23	4	19	0
CHCF	29	29	0	0
CIM	26	26	0	26
CIW	9	0	9	9
CMC	41	0	41	41
CMF	24	6	18	24
COR	27	4	23	0
CRC	49	4	45	46
CTF	22	8	14	14
CVSP	14	14	0	0
DVI	1	0	1	1
FSP	18	8	10	10
HDSP	21	21	0	0
ISP	22	22	0	22
KVSP	20	5	15	0
LAC	23	1	22	21
MCSP	23	23	0	6
NKSP	25	25	0	25
PBSP	33	0	33	0
PVSP	23	23	0	0
RJD	25	25	0	3
SAC	15	15	0	4
SATF	27	0	27	27
SCC*	11	0	11	0
SOL	24	24	0	24
SQ	10	8	2	10
SVSP	21	0	21	0
VSP	16	1	15	16
WSP	28	6	22	0
Totals	766	378	388	373

¹ Includes filters with higher efficiency (MERV-14).² At CIW, CRC, CTF, FSP and SQ, the air handling units of the housing units listed in this column do not recirculate any amount of

* System design does not allow for installation of MERV-13 filters due to resulting decreased air flow. MERV-11 is the highest efficiency that provides sufficient airflow.

MERV-13 Filter Installation Schedule**(Based on Information as of 7/16/21)**

Institution	Estimated Installation Date
CCC	July 2021
CCI	October 2021
CCWF	September 2021
CEN	August 2021
CMC	October 2021
CMF	August 2021
COR	September 2021
KVSP	August 2021
LAC	October 2021
PBSP	October 2021
SATF	September 2021
SVSP	August 2021
VSP	October 2021
WSP	August 2021